

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)



INDIAN BANK

Zonal Office Ahmedabad
3rd Floor, 301-311, Neelkanth Avenue
1, Opp. Gujarat Vidhyapeeth, C U
Shah College Road, Nr. Income Tax
Cross Road, Ashram Road,
Ahmedabad- 380014
Email: zoahmedabad@indianbank.co.in

INVITATION OF TENDER

**RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS
& REFILLING OF FIRE EXTINGUISHERS
(INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)
FOR THE INDIAN BANK OFFICES/BRANCHES INCLUDING ATM SITES
UNDER AHMEDABAD ZONE**

Tender Documents Availability : **05th Mar 2026**
Last Date of Tender Submission : **1700 Hrs on 25th Mar 2026**
Date of Technical Bid Opening : **1430 Hrs on 27th Mar 2026**

EMD: 5000/-

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

SCHEDULE OF EVENTS

Tender Bid Document Availability	Bidding document can be downloaded from website www.indianbank.in from 05th Mar 2026 .
Last date and time of submission of Bids	25th Mar 2026- 1700 HRS
Opening of Technical Bids	27th Mar 2026- 1430 HRS Bidders may depute authorized representatives during the opening of Technical Bids with valid ID card of Bidder Company/ Firm. However Technical Bids would be opened even in the absence of any or all of the Bidders representatives.
Contact Official and Mobile No	Zonal Security Officer- 99807 87488 (during business hours)
Address for communication and submission of bid	Indian Bank, Zonal Office Ahmedabad, 3 rd Floor, 301-311, Neelkanth Avenue 1, Opp. Gujarat Vidhyapeeth, C U Shah College Road, Nr. Income Tax Cross Road, Ashram Road, Ahmedabad- 380014
All correspondence relating to this Tender should be sent to email id	zoahmedabad@indianbank.co.in
Cost of the Tender Bid document	NIL
Earnest Money Deposit	5000/-

IMPORTANT DEFINITIONS

TERMS	DEFINITIONS
Bank	Indian bank
ZO	Zonal Office Ahmedabad, 3 rd Floor, 301-311, Neelkanth Avenue 1, Opp. Gujarat Vidhyapeeth, C U Shah College Road, Nr. Income Tax Cross Road, Ashram Road, Ahmedabad- 380014
Branch	Indian Bank branch/ Offices (including ATM site, if available)
TENDER	Request for Quotation/ Tender
Vendor	Participating Company/ Firm/ Manufacturer/ Authorized dealer
OEM	Original Equipment Manufacturer
Tender	Tender, Bid documents
Bidder	A Firm/Company/OEM/Authorized dealer participating in TENDER
FE	FIRE EXTINGUISHERS
NA	Not Applicable

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

NOTICE INVITING TENDER

Rate contract for Supply and Installation of Fire Extinguishers & Refilling of Fire Extinguishers
(including maintenance of existing Fire Extinguishers)

INTRODUCTION

1. Indian Bank, Zonal Office Ahmedabad, invites sealed quotations in two bid system for rate contract for New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) at branches/ offices under its jurisdiction comprising of Ahmedabad and nearby Districts (Ahmedabad, Panch Mahals, Gandhinagar, Kheda, Sabar Kantha, Mehasana, Anand, Patan, Dahod, Aravalli) from reputed Firms/Manufacturers/Authorized dealers. The **first bid** shall be technical bid and the sealed envelope of Technical Bid shall contain the details of OEM, Acceptance of terms and conditions, and other eligibility conditions, etc. The **second bid** shall be financial bid and the sealed envelope of Financial Bid shall contain the price information of the product and services in prescribed format as per the annexure. **Financial bids shall invariably be submitted in sealed envelope. Any financial bid found open for any reason shall make the bidder ineligible for participation.**

2. India Bank, Zonal Office Ahmedabad has a network of 73 Branches/ ATMs and 07 Special Branches, Zonal Office and 1 offsite ATMs/ offices function directly/ indirectly under the Zonal office.

ELIGIBILITY CRITERIA

3. The eligibility criteria for rate contract are given below and only those agencies that fulfill the following criteria are eligible to bid.

a) The prospective bidder should be a registered company/ firm including manufacturers (OEMs as described in point no.7) or their authorized dealers, capable of providing FIRE EXTINGUISHERS for New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) and should be in business for at least 3 years (Adequate Proof like work orders/empanelment letters to be enclosed).

b) The OEM/ its authorized dealers must have his own registered office with adequate technical manpower and material at Ahmedabad or any of the district where zonal jurisdiction extends. Proof for the same to be submitted as

- i. Lease Agreement for hired/ leased premises or Ownership Documents for Own Premises
- ii. Registration Certificate under Shops and Establishment Act.

Note: Submission of Both Documents are Mandatory

The Bank may inspect the facilities of the Manufacturer/ Firm/ Company/ Dealer/ Vendor to verify the genuineness and to ensure the conformity with the details given. (Details to be provided in format Annexure II).

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

- c) There is no minimum limit to annual turnover. However, the prospective applicant/bidder should be in profit for last three years. (Relevant copies of Balance Sheets with profit loss statement and IT return to be submitted).
- d) The prospective applicant/bidder must be on panel of at least one PSUs / Banks (Public/Private)/NBFCs/Government Departments and have at least one running contract with PSU/ Banks (Public/Private)/NBFCs/Government Department. Latest Performance report/ certificate (issued on or after 05th Mar 2026) of running contract for same to be enclosed.
- e) The bidder should have valid PAN, GST registration number etc., allotted by competent authorities.
- f) The prospective applicant/bidder should have requisite trade/manufacturing/factory license from appropriate authority (BIS).
- g) The Company/ Firms/ Authorized dealer which participates in the Tender process shall only be eligible for rate contract. **All existing empaneled vendors have to apply afresh.** Telephonic/ email intimation to prospective applicants for participating in TENDER will not be initiated from Zonal Office, even to the existing vendors.
- h) Vendor should have valid license in accordance to IS 15683/2018 for supply of Extinguishers or agreement with OEM having IS 15683/2018 Licenses (Copy of Proof to be submitted) Manufacture and Supply.**
- i) Care and Maintenance/ Refilling of Fire Extinguisher shall be conforming to IS 2190: 2024.**
- j) Bidders to be in position of supply Fire Extinguishers as per Bank's requirement as per the technical specifications mentioned in succeeding paragraphs (Bidder should be ready for Practical demonstration and Display if Bank desired at Bank's premises. All Technical specification will be verified therein). OEM Owned Product specifications shall also be displayed.
- k) Bidders to duly fill all technical/ financial details asked by Bank without leaving blank.
- l) Authorized representative of bidder to sign and seal all pages of tender document.
- m) **Facility /license for refilling** (own/ with other eligible firms). In case of tie up with other firms; license, registration with local administration & agreement with bidder to be attached.

NATURE AND SCOPE OF WORK

4. New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) at branches/ offices of under the jurisdiction of Indian Bank, Ahmedabad Zone scattered in various locations at Ahmedabad or districts where Zonal Office Jurisdiction extends. Concerned Vendor will have to enter into an agreement (as per the format decided by the bank) with the Zone and shall start the work from the date of issuance of the work order. The work order for new installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) shall be placed by the Zone as per requirement basis.

- a) Please note that the invitation of tender is for new installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) installed in all existing Branches, ATMs & offices of the Zone. However, new installations

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

are subject to requirement of Bank. **Bank has discretion to revise the scope of work upward / downward as per its requirement.**

b) It is to bring to the notice of prospective Applicants that they will be required to supply and replace newly installed components at their own cost during warranty period and the warranty period of each component has to be specified in the tender document.

c) The Vendor will maintain the data sheet of Fire Extinguishers of each branch/ office with details such as manufacturing date, date of installation, warranty valid up to, AMC carried out on, AMC due on, etc. **A copy of the Branch / Office wise data sheet of Fire Extinguishers to be provided to the Zonal Office as well as to the concerned Branch/office.** The data sheet indicating type of Fire Extinguisher, Capacity, Last Pressure test/ refilling date, next due date shall be pasted on each fire Extinguisher

d) The Vendor must ensure Half-yearly AMC visit. **There should be a gap of minimum 45 days between two AMC visits.** During AMC Visit all preventive maintenance activities to be carried out and recorded.

e) The vendor will follow the norms and procedures laid down for installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers).

f) The vendor will carry defective components to his own workshop for repair only after taking written prior approval of the Branch Manager.

g) The detail specification for new installation will be decided by the Zonal Office.

h) The vendor will impart training and live firefighting demo to staff members about operating procedure during the AMC visit. **Vendor should also submit the copy of above exercise done at Branch by duly signed by the branch head.**

i) Vendor shall follow all norms during the refilling of fire extinguishers conform IS 2190: 2024. After refilling; proper stickers to be displayed in all cylinders containing the information such as Pressure testing date, Refilling Date, Next refilling/ pressure testing date, type of Fire Extinguishing media, weight of fire extinguishing media along with vendor contact details (Copy of the information sheets to be enclosed)

APPLICATION FORM

5. The application form to be filled and submitted as per Annexure I (Cover Letter) and Annexure II (Bidder Profile). The tender notice should be signed by authorized signatory on each page with official seal and enclosed along with the Application Documents.

RATE CONTRACT PROCESS

6. The selection of Bidders for supply, new installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) shall be done in two bid format as under.

a) **PHASE I - TECHNICAL BID:**

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

- i) Technical bid shall be submitted in a separate sealed envelope. It should be super scribed in bold **“Technical Bid for New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers)”**.
- ii) Technical bid shall contain Annexure I (Application), Annexure II (Bidder profile) and Annexure III (Testimonials).
- iii) The Applications of the bidders will be valid for 120 days from the date of opening of the same.
- iv) The selection/ short listing of the applications so received will be done by carrying out evaluation and checking of various parameters/ criteria fixed by the bank.
- v) The technical bids shall be opened at **1430 Hrs on 27th Mar 2026**, or on any suitable date as decided by the bank’s committee for the purpose. If any change in the date will be published in this website.
- vi) An undertaking that firm is capable of undertaking installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) work in rural and far away areas where majority of bank’s branches are located (To be enclosed with Technical Bids).

b) PHASE II - FINANCIAL BID

- i) Financial bid shall be submitted in a separate sealed envelope. It should be super scribed in bold **“Financial Bid for New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers)”**.
- ii) Financial bids of only technically qualified short listed bidders will be opened. Bank’s evaluation of the financial bids will take into account the status of compliance of terms and conditions.
- iii) The Financial Bid should contain all relevant rates and charges (Service Charge / Installation Charge), taxes and the rates should be quoted in Indian Rupees only. GST component must be explained (inclusive/exclusive) clearly. In case of any ambiguity during comparing quoted prices arouses because of GST, Bank may take a call to disqualify such bids.
- iv) The Bank may select multiple vendors for entering into rate contract and becoming L1 is not the only criteria. Decision of the same is completely binding with Bank.

c) Interested Bidders may arrange to submit their application duly complete in all respects in a sealed envelope cover superscripted "Application for New Installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers)" and this envelope should contain two separate envelopes super scripted as details below:

Envelope 1: Technical Bid

Envelope 2: Financial Bid

And, it should reach on or before **1700 Hrs on 25th Mar 2026**, at the following address:

The Zonal Manager
Zonal Office Ahmedabad, 3rd Floor, 301-311,

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

Neelkanth Avenue 1, Opp. Gujarat Vidhyapeeth,
C U Shah College Road, Nr. Income Tax Cross Road,
Ashram Road, Ahmedabad- 380014

PERFORMANCE AND PRODUCT CERTIFICATION:

7. The Bidders should have the following product certification and other criteria: -
- a) **Product Certification:** The products of the Bidder must have certification of quality given by the Bureau of Indian Standard (BIS) and acceptable to Bank. The products should be based on latest technology for the specific requirement.
 - b) **OEM Certificate:** The Bidder should have OEM certificate along with confirmation that they would supply spare parts for the quoted components for a period of 5 years from the date of installation.
 - i) OEM should be ISO 9001 certified.
 - ii) Documents of Manufacturing license/ Registration of the OEM factory need to be submitted for verification.
 - iii) Product Certification copies to be attached as per the BIS specifications (IS 15683: 2018). License should be available for each product.
 - v) The firm should produce authorization Docs from OEM for its offered makes in original.
 - vi) Multiple brand Techno-commercial bids from single bidder will be rejected.
 - vii) Serial number & IS certificate of products to be provided by the OEM.
 - viii) Audit for Banks, whether actual material is provided or not, needs to be done by OEM as and when required by Bank without any additional cost.
 - c) **Past Record:** The Bidder or their entities should not have been blacklisted by any PSU/PSB/Government Organization in past 3 years and undertaking in this regard to be submitted.
 - d) Bidders A/c should not be classified as NPA (Non performing Assets) by any bank. A self-declaration in this regards to be submitted by bidder along with Bid Documents.

PAYMENT TERMS

8. No advance payment shall be made against purchase order
- i) Payments shall be made after delivery & installation of new Fire Extinguishers at per site Basis. The payment shall be made against delivery challans and invoices and commissioning report duly signed by the Branch Manager.
 - ii) The vendor empaneled advised to have a Bank Account with Indian Bank for operational convenience
 - iii) The Annual Maintenance Charges shall be paid once in three months' subject to satisfactory maintenance for the previous three months. Vendors failing to render requisite maintenance service visits shall be paid only on the pro rata Basis for the number of mandatory service visits.

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

- iv) All Annual Maintenance Charges shall be paid from Zonal Office only.**
- iii) All other terms and conditions are spelt out in the Terms and conditions attached to this tender.

TERMS & CONDITIONS OF CONTRACT (TCC)

9. Indian Bank's Right to Accept/ Reject any/or all Application:
- i) Indian Bank reserves the right to accept/ reject any or all application and to annul the rate contract process and accept/ reject all applications at any time prior to TENDER process or any time after TENDER process, without thereby incurring any liability to the affected Bidders or any obligation to inform the affected Bidders of the grounds for Indian Bank action.
 - ii) Indian Bank's Right to Split the Service Area Work: Indian Bank reserves the right to split and distribute the work among the participating Bidders partly or fully amongst the bidders agreeing at lowest quoted rates. Indian bank reserves the Right to Issue Clarifications, Addendums, and Corrigendum etc.
 - iii) Discrepancies or omission, if found by any bidder, in the terms & conditions of the tender document, or if any clarification is sought by the bidder, a written request, to the application inviting authority, for correction / clarification or interpretation can be submitted up to **1700 Hrs, 27th Oct 2025 at zoahmedabad@indianbank.co.in**. Indian Bank can at any time issue clarifications, addendums or corrigendum. The same will be published in the bank's website. The Bidders are advised to regularly visit the Bank's website.

CONDITIONS FOR APPLICATION REJECTION/ CANCELLATION:

10. Bidder's application for rate contract or the registration after rate contract of Bidder may be rejected / cancelled on the following grounds:
- i) Any effort by Bidder/applicant to influence Indian Bank's decisions on evaluation and registration process may result in rejection of application or cancellation of registration.
 - ii) Conditional applications will not be considered and will be rejected summarily.
 - iii) Submission of false/fake Application Documents or if the information provided by the Bidder is found to be incorrect/misleading at any stage / time during the rate contract process or thereafter.
 - iii) Applications received by Indian Bank after the last date and time prescribed for receipt of application or applications without signature of person(s) duly authorized on required pages of the application or applications without power of authorization and any other document consisting of adequate proof of the ability of the signatory to bind the Bidder shall be rejected.
 - iv) Malpractice / attempt to influence / Manipulation of rates at Zonal level by itself or by cartelization shall be viewed very seriously. If such a situation comes to the notice and/ or there are reasons/ circumstances for Indian Bank to believe so, the concerned Bidder will be called in to give justification of rates quoted by them to the Zonal Office. If

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

they are not able to give a proper/ satisfactory justification of their quoted rates, their rate contract / enlistments are liable to be cancelled.

- v) If the Bidders are found, subsequent to their registration, not complying with, any of the eligibility criteria.
- vi) If the performance and services of the bidder have been found poor or sub-standard.
- vii) If it is found that false/amplified/manipulated bill(s) raised by vendor.
- vii) Any other grounds as decided by Indian Bank management after due diligence.
- Viii) non suitability of desired standards/ specifications

MONITORING OF PERFORMANCE AND OTHER CONDITIONS:

11. The Bidder's performance on the job will be constantly monitored for quality, adherence to the Safety Regulations, Labour / Statutory regulations, Conduct / Discipline etc, while executing jobs. Any deviations from stated conditions can lead to appropriate deterrent action as deemed fit by Indian Bank.

- i) Indian Bank reserves the exclusive right and absolute discretion to call for tenders for any job or otherwise as deemed fit from open market, even during the validity of the rate contract period.
- ii) Successful rate contract by Indian Bank is no guarantee of any future award of work or inclusion on a particular tender list.

EMD AMOUNT:

12. EMD Amount shall be exempted as per the prevailing Govt. Guidelines

JURISDICTION AND GOVERNING LAW:

13. All disputes or differences whatsoever arising between the parties out of or in relation to the construction/ meaning and operation or effect of this rate contract document or breach thereof shall be settled amicably. If, however, the parties are not able to solve it amicably the same shall be settled by arbitration in accordance with the Arbitration and Conciliation Act 1996 (with latest amendments) and the award made in pursuance thereof shall be binding on the parties. The Arbitrator/Arbitrators shall give a reasoned award. Any appeal will be subject to exclusive jurisdiction of courts at Ahmedabad.

LIQUIDATED DAMAGES:

14. Any delay in completion of the work over the stipulated period will attract penalty of 0.5% of the contract value (site Basis) per week subject to maximum of 10% of the contract value. The Bank reserves its right to recover this amount by any mode, which includes adjusting from any payment to be made by the Bank to the Vendor.

VALIDITY PERIOD:

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

15. The successful Bidders/ Firms/ Vendors will remain in the list of the Bank for **three year** from the date of contract or till the completion of next contract period at the Bank's own discretion (whichever is earlier).

- i) The Rate contract will be valid for **(03) Three Year. Initially work will be allotted to one year (1) and will be renewed on yearly basis on satisfactory performance up to maximum three years.** On successful completion of first year, renewal for second year will be subject to the satisfactory performance and review by Security Department. Revision of rates during the contract period will not be entertained by Bank for whatsoever reasons.
- ii) Contract will be valid only, if all eligibility criteria mentioned in the Tender Notice are fulfilled during the entire contract period.
- iii) If the service provided by bidder is found to be poor and unsatisfactory or if at any point of time during the Contract or it is found that the information provided by bidder is false during the tender process, the Bank reserves the right to cancel the contract. Bank's decision in this regard will be final.

BANK'S DISCRETION:

- 16) Bank reserves the right to reject an offer under any of the following circumstances:
- i) Incomplete offer and/or all documents not attached.
 - ii) Offer is not in conformity with the terms and conditions stipulated in this document.
 - iii) Specifications stipulated in TENDER are not met with.
 - iv) If Financial Bid and Technical Bid are not submitted in sealed envelope separately.
 - v) Financial Bid format differs from actual Financial Bid format of Annexure IV.
 - vi) Violates any terms and conditions in the TENDER document.
 - vii) If found that the information provided in the offer is false.

EVALUATION CRITERIA

17. Technical Bids:

- i) The Technical Bid should be complete in all respects and contain all information asked for in this document. It should not contain any price information.
- ii) The Technical Bid must be submitted in an organized, numbered and structured manner (spiral binding will be appreciated). No brochures/ leaflets etc should be submitted **in loose form.**
- iii) Technical bid should contain all testimonials as mentioned in previous section of this TENDER document.
- iv) Bank will evaluate the technical bid considering the technical and functional parameters of bidder and evaluation matrix decided by bank.

18. Commercial Bids:

- i) Commercial bids of only technically qualified short listed bidders will be opened. Bank's evaluation of the commercial bids will take into account the status of compliance

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

of terms and conditions. The Price Bid should contain all relevant rates and charges (Service charge / installation Charge) and the rates should be quoted in Indian Rupees only.

ii) Cost economics of the tender will be decided on the Basis of Total Cost of Equipment/cost of components having low MTBF/ services as enumerated in Annexure-I

PATENTS RIGHTS

19. The Vendor shall indemnify the purchaser against all third party claims on infringement of patent, trademark or industrial design rights arising from use of the Goods, or any part thereof in India.

i) The vendor shall, at their own expense, defend and indemnify the Bank against all third party claims of infringement of intellectual Property Right, including Patent, trademark, copyright, trade secret or any part thereof in India or abroad.

ii) The Vendor shall expeditiously extinguish any such claims and shall have full rights to defend it there from. If the Bank is required to pay compensation to a third party resulting from such infringement, the Vendor shall be fully responsible for, including all expenses and court and legal fees.

iii) The Bank will give notice to the Vendor of any such claim without delay, provide reasonable assistance to the Vendor in disposing of the claim, and shall at no time admit to any liability for or express any Intent to settle the claim.

iv) The Vendor shall grant to the Bank a fully paid-up, irrevocable, non- exclusive license throughout the territory of India or abroad to access, replicate and use software (and other software items) if any, provided by the Vendor, including-all inventions, designs and marks embodied therein in perpetuity.

TERMINATION FOR INSOLVENCY

22. The Bank may at any time terminate the Contract by giving written notice to the Bidder, if the Bidder becomes bankrupt or otherwise insolvent. In this event, termination will be without compensation to the Bidder.

LIABILITY

23. Bidder's aggregate liability under the contract shall apply to third party claims for bodily injury/ electric shock (including death) and damage to real property (due to malfunction of equipment) and tangible personal property caused by bidder's gross negligence/ lapse or due to below standard equipment used by Bidder.

i) The Bidder shall be liable for any indirect, consequential, or special damages due to malfunction of the security equipment's under the agreement / purchase order.

WARRANTY

24. The offer must include on-site warranty of at least one year or as offered by the OEM but not less than one year from the date of installation and replacement of components however there should not be any additional cost for the warranty period.

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

- i) Vendor shall be fully responsible for the manufacturer's warranty in respect of proper design, quality and workmanship of all equipment, accessories, etc., covered by the offer.
- ii) The Vendor must warrant all equipment, accessories, spare parts etc, against any manufacturing defects during the warranty period.
- iii) During the warranty period the Vendor shall maintain the equipment and repair / replace all the defective components at the installed site at no additional charge of whatsoever nature to the Bank.

DELIVERABLES & TIMELINES

25. The Vendor should ensure that the defects reported in the Fire Extinguishers or its components, software, etc supplied to the Bank on any working day is set right and in no case later than the two working day for branches/ Offices/ ATMs in Ahmedabad Zone. The defect will be reported by the office/branch directly to vendor, may be in the form of oral, telephone, notice, email, or any other mean of communication. The vendor shall generate a complain number for tracking the complaint status. In case, the system or any equipment cannot be repaired within the stipulated period, the Vendor should provide a replacement till the system/ equipment is returned duly repaired.

SPECIFICATION/REFILLING/MAINTENANCE

26. The detailed technical description is enumerated below. The specifications given are as per minimum requirement. Vendors can quote equivalent or higher technical specifications to meet the Bank's requirements. However, no weightage would be given for higher configurations. All components should be BIS certified. A half-yearly visit to the offices/branches shall be mandatory for checking the pressure and condition of all the fire extinguishers.

a) SPECIFICATIONS FOR PORTABLE FIRE EXTINGUISHER CARBON DIOXIDE 4.5 KGS (IS 15683: 2018)

S No	Parameters	Specification
1	Fire Extinguisher	4.5 Kg Capacity Portable CO ₂ Fire Extinguisher
2	BIS Specification	IS 15683: 2018 (IS standard must be displayed in Cylinder)
3	Warranty	Minimum Five Years
4	Suitability of Type of Fires	B & C (Non conductive agent for electrical use without risk to operator)
5	Extinguisher Type	Stored Pressure
6	Operation Position	upright
7	Extinguishing Media	It shall be filled with CO ₂ gas conforming to BIS 15222 (Latest revisions) in liquefied conditions and shall have maximum filling ratio of 0.667 kg/l. The CO ₂ , gas to be filled in shall be moisture free and 99 percent pure and shall conform to the requirement of IS 15222. Certificate to this effect shall be produced at the time of supply of material. CO ₂ gas disappears quickly leaving no residue
8	Fill density	The fill density for Carbon dioxide fire extinguisher shall not exceed 0.667 kg/l

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

9	Filling Tolerance	The actual charge of fire extinguisher shall be nominal charge within +0 % to + 5 percent by mass
10	Weight	The weight of a fully charged portable fire extinguisher shall not be more than 17 Kg.
11	Operating temperature	Fire extinguisher shall be capable of operating reliably within the temperature range of -10o C to + 60o C.
12	Minimum Throw distance with Effective Discharge Time	The Minimum throw distance of CO2 fire extinguisher shall not be less than 2 m in Minimum discharge time of 8 Second.
13	Discharge Horn	The horn of a carbon dioxide fire extinguisher shall be fitted with a handle to protect the hand of the operator against cooling during use. The horn connection shall be made in such a manner as to prevent loosening or detachment. If the connection is a screw thread, then it shall be secured against loosening by either mechanical means or a suitable adhesive.
14	Control valve	The Fire Extinguisher shall have wheel valve to operate and discharge gas. Safety pin shall be fitted to avoid accidental operations of the Fire Extinguisher (As per IS 3224)
15	Desired Class B Fire Rating	55 B
16	Dimension of fire Extinguisher (external)	Diameter 140 ± 10 mm
17	Service Pressure (High)	≥ 19 bar
18	FINISH :	The inside and outside surface shall be smooth, and the material section shall be uniform.
19	ANTI CORROSIVE TREATMENT	All external surfaces of the body and internal part shall be completely provided with suitable "Anti Corrosive Treatment" compatible with MOC of Fire Extinguisher. There shall be no visible uncoated area externally.
20	Mounting Bracket	Mounting Bracket shall conform to requirements stipulated in IS 15683:2018 (Latest amendment)
21	MARKING ON Fire EXTINGUISHER	Each extinguisher shall be clearly and permanently marked with the following information by etched or embossed metal nameplates or band, or pressure sensitive nameplate attached to the side of extinguisher body as per Clause no 10.2 of IS 15683:2018 (latest amendments) Year of Manufacture with at least two digits of the calendar year. <ul style="list-style-type: none"> · Factory Test pressure on body of the cylinder · Date of Manufacture · Name of the manufacturer · Temperature rating. · The statement 'Recharge immediately after any use ' · Model Number · Fire rating · Sr no of fire extinguisher · Classification of Fire Extinguisher

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

		<ul style="list-style-type: none"> · Gross Mass · Operating instructions · Recharging instruction. · Inspection and maintenance instructions · BIS certification mark: The Fire Extinguisher shall be marked with the BIS Standard Mark.
22	Shell or Body of Cylinders	Steel Conforming to IS 7285
23	Discharge Valve	As per Clause no 9.5 of IS 15683 :2018 (latest amendments)
24	Plastic Components	As per Clause no 9.7 of IS 15683 :2018 (latest amendments)
25	Safety Device	As per Clause no 9.6 of IS 15683 :2018 (latest amendments)
26	Carrying Handle	As per clause no 9.3. of IS 15683:2018 (latest amendments)

Refilling/Maintenance of 4.5 Kg CO₂ Fire Extinguisher

1. Every carbon Di-oxide extinguisher installed in premises shall be hydraulically pressure tested once in five years. There shall not be any leakage or visible distortion. Extinguisher which fails in these requirements shall be replaced.
2. Always discharge gas from extinguisher before sending for HPT and refilling.
3. Refilling should be done when cylinder weight is reduced by 10% or more than 10% from gross weight of Cylinder or after Hydraulic pressure Test (HPT).
4. Checked the vendor license and demand for supply of HPT certificate after HPT of Cylinder.
5. Fire Extinguisher shall comply with IS 15683:2018.
6. Maintenance to be done in accordance to IS 2190:2024.
7. Shelf life of carbon Di-oxide extinguishers is 15 years only from manufacturing date.

b) SPECIFICATIONS FOR PORTABLE FIRE EXTINGUISHER STORED PRESSURE 4 KGS ABC TYPE (MAP 40)

SI No	Values	Specification
1.	Scope of work	Supply of Portable extinguisher 4 kgs-confirming to IS -15683:2018 latest revision and ISI marked complete with all fittings.
2.	Extinguishing Media	ABC Dry Powder (Mono Ammonium Phosphate based)-MAP 40 {Powder shall conform to IS 4308}
3	BIS Specification	IS 15683: 2018
4	Fire Class Suitability	Class A (ordinary combustibles), B (flammable liquids), and C (flammable gases).
5	fire rating	2A,55B, C
6	Cylinder body	Mild steel constructed via deep drawn or MIG welding process. Designed to withstand required working and test pressures. Internal body shall be anti-corrosion plated. External surface powder coated type.
7	Valve Material	Plated Brass (Squeeze Grip type). Equipped with safety pressure release device

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

8	Warranty	Cylinder: Minimum 5 years warranty from the date of supply Other Components: Minimum 1 Year Warranty
9	Handle/lever Material	Stainless steel
10	Operating Pressure(@70 deg F)	15 KGF/CM2
11	Temperature Range(Deg C)	-10 degree cent. to 55 degree Cent.
12	Nominal discharge time (Sec)	10-15 sec
13	Discharge horn	Flexible PVC braided hose fitted with end connection
14	Hose	Min. bursting pressure shall be 55 kgf/cm ² .
15	Discharge Range (mtr)	4 Mtr
16	Operating type	Squeeze grip
17	Pressure Gauge	Dial Type pressure gauge with colour coded indication & Clearly indicating operating pressure zone.
18	Test Report & certificates	IS approved Certificate.
19	Test Pressure	35 KGF/CM2
20	Recommended area for Utilization	Class A, B and C i.e. Wood, Paper, Petroleum and electrical equipment.
21	Marking	Extinguisher permanently marked with the following information: a) Manufacture's Name or Trade-mark, b) Year of Manufacture of the cylinder and test pressure. c) Method of operation in prominent letters. d) ISI Marking, CE marking
22	Other specifications	<ul style="list-style-type: none"> • Hydraulically tested as per standard and passed through anti-corrosive treatment • OEM Technical data sheet to be enclosed in each fire extinguisher

Refilling/Maintenance of 2.0 Kg ABC Fire Extinguisher (Stored Pressure Type)

1. Every Dry chemical powder extinguisher installed in premises shall be hydraulically pressure tested once in five years. There shall not be any leakage or visible distortion. Extinguisher which fails in these requirements shall be replaced.
2. Always emptied out Powder from extinguisher before sending for HPT and refilling.
3. Refilling should be done when pressure is drop 10% or more than 10% in stored pressure type and caking of powder in DCP cartridge type or after Hydraulic Pressure test (HPT).
4. Checked the vendor license and demand for supply of HPT certificate after HPT of Cylinder.
5. Fire Extinguisher shall comply with IS 15683:2018.
6. Maintenance to be done in accordance to IS 2190:2010.
7. Shelf life of DCP extinguisher is 10 years only from manufacturing date.

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

C) SPECIFICATIONS FOR PORTABLE FIRE EXTINGUISHER STORED PRESSURE 2 KGS ABC TYPE (MAP 40)

SI No	Values	Specification
1.	Scope of work	Supply of Portable extinguisher 2 kgs-confirming to IS -15683:2018 latest revision and ISI marked complete with all fittings.
2.	Extinguishing Media	ABC Dry Powder (Mono Ammonium Phosphate based)-MAP 40 {Powder shall conform to IS 4308}
3	BIS Specification	IS 15683: 2018
4	Fire Class Suitability	Class A (ordinary combustibles), B (flammable liquids), and C (flammable gases).
5	fire rating	1A,34B, C
6	Cylinder body	Mild steel constructed via deep drawn or MIG welding process. Designed to withstand required working and test pressures. Internal body shall be anti-corrosion plated. External surface powder coated type.
7	Valve Material	Plated Brass (Squeeze Grip type). Equipped with safety pressure release device
8	Warranty	Cylinder: Minimum 5 years warranty from the date of supply Other Components: Minimum 1 Year Warranty
9	Handle/lever Material	Stainless steel
10	Operating Pressure(@70 deg F)	15 KGF/CM2
11	Temperature Range(Deg C)	-10 degree cent. to 55 degree Cent.
12	Nominal discharge time (Sec)	10-15 sec
13	Discharge horn	Flexible PVC braided hose fitted with end connection
14	Hose	Min. bursting pressure shall be 55 kgf/cm ² .
15	Discharge Range (mtr)	4 Mtr
16	Operating type	Squeeze grip
17	Pressure Gauge	Dial Type pressure gauge with colour coded indication & Clearly indicating operating pressure zone.
18	Test Report & certificates	IS approved Certificate.
19	Test Pressure	35 KGF/CM2
20	Recommended area for Utilization	Class A, B and C i.e. Wood, Paper, Petroleum and electrical equipment.
21	Marking	Extinguisher permanently marked with the following information: a) Manufacture's Name or Trade-mark,

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

		b) Year of Manufacture of the cylinder and test pressure. c) Method of operation in prominent letters. d) ISI Marking, CE marking
22	Other specifications	<ul style="list-style-type: none"> • Hydraulically tested as per standard and passed through anti-corrosive treatment • OEM Technical data sheet to be enclosed in each fire extinguisher

Refilling/Maintenance of 2.0 Kg ABC Fire Extinguisher (Stored Pressure Type)

1. Every Dry chemical powder extinguisher installed in premises shall be hydraulically pressure tested once in five years. There shall not be any leakage or visible distortion. Extinguisher which fails in these requirements shall be replaced.
2. Always emptied out Powder from extinguisher before sending for HPT and refilling.
3. Refilling should be done when pressure is drop 10% or more than 10% in stored pressure type and caking of powder in DCP cartridge type or after Hydraulic Pressure test (HPT).
4. Checked the vendor license and demand for supply of HPT certificate after HPT of Cylinder.
5. Fire Extinguisher shall comply with IS 15683:2018.
6. Maintenance to be done in accordance to IS 2190:2010.
7. Shelf life of DCP extinguisher is 10 years only from manufacturing date.

D) AUTOMATIC MODULAR FIRE EXTINGUISHER (MAP 90)- 05 KG

ABC Dry chemical powder Automatic Modular Fire Extinguisher, the release temperature can be adjusted to suit prevailing conditions.

Technical Data

Utilization Temperature: 57 degree cent. to 107 degree cent.

Powder: Conform to IS 4308

Fire Rating : 3A: 55B:C

ABC Powder: MAP 90 based

Cylinder/ Body:

- a) Made of high quality deep drawn mild steel
- b) Internal surface : Anti Corrosion coated.
- c) External Surface: Powder Coated
- d) Designated for ceiling suspended installation

Operating Mechanism:

- a) Automatic Operation through heat sensitive bulb/ fusible element
- b) Bulb temp (Activation): 67 Deg,C +/- 5 Deg,C
- c) Automatic discharge when temperature reaches the preset level.

Pressure

Working Pressure : 15 KGF/ CM2

Test Pressure: 35 KGF/ CM2

Discharge Time

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

Minimum 8-12 Seconds

Discharge pattern

360 degree radial discharge ensuring uniform distribution in the protected area

Coverage Area

Approximate 8-12 square meters coverage area

Recommended mounting height

2.5 M to 3.5 m from floor level

Operating Temperature Range

-10 Deg.C to +55 Deg.C

Marketing & labelling

Each extinguisher shall be permanently marked with:

- a) Manufacturers Name and Address
- b) Capacity and Type of Fire Extinguisher
- c) Month and Year of Manufacturer
- d) Type of Extinguishing Agent (MAP 90 based ABC Powder)
- e) Operating Instructions
- f) Refilling and Servicing Instructions

Accessories

Each unit shall be supplied with:

- a) Ceiling mounting Bracket/ suspension arrangement
- b) Fasteners and Installation hardware
- c) Instruction Card

Warranty

Cylinder: Minimum 05 Years warranty from date of supply.

Accessories and Operating Mechanism: Minimum 1 year

Certification/ Documentation

- a) Manufacturer's Test Certificate
- b) Powder Test Certificate confirming MAP 90 Content
- c) Product Compliance Certificate

E) AUTOMATIC MODULAR FIRE EXTINGUISHER (MAP 90)- 10 KG

ABC Dry chemical powder Automatic Modular Fire Extinguisher, the release temperature can be adjusted to suit prevailing conditions.

Technical Data

Utilization Temperature: 57 degree cent. to 107 degree cent.

Powder: Conform to IS 4308

Fire Rating : 4A: 89B:C

ABC Powder: MAP 90 based

Cylinder/ Body:

- e) Made of high quality deep drawn mild steel
- f) Internal surface : Anti Corrosion coated.
- g) External Surface: Powder Coated
- h) Designated for ceiling suspended installation

Operating Mechanism:

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

- d) Automatic Operation through heat sensitive bulb/ fusible element
- e) Bulb temp (Activation): 67 Deg,C +/- 5 Deg,C
- f) Automatic discharge when temperature reaches the preset level.

Pressure

Working Pressure : 15 KGF/ CM2

Test Pressure: 35 KGF/ CM2

Discharge Time

Minimum 12-15 Seconds

Discharge pattern

360 degree radial discharge ensuring uniform distribution in the protected area

Coverage Area

Approximate 15-20 square meters coverage area

Recommended mounting height

2.5 M to 3.5 m from floor level

Operating Temperature Range

-10 Deg.C to +55 Deg.C

Marketing & labelling

Each extinguisher shall be permanently marked with:

- g) Manufacturers Name and Address
- h) Capacity and Type of Fire Extinguisher
- i) Month and Year of Manufacturer
- j) Type of Extinguishing Agent (MAP 90 based ABC Powder)
- k) Operating Instructions
- l) Refilling and Servicing Instructions

Accessories

Each unit shall be supplied with:

- d) Ceiling mounting Bracket/ suspension arrangement
- e) Fasteners and Installation hardware
- f) Instruction Card

Warranty

Cylinder: Minimum 05 Years warranty from date of supply.

Accessories and Operating Mechanism: Minimum 1 year

Certification/ Documentation

- d) Manufacturer's Test Certificate
- e) Powder Test Certificate confirming MAP 90 Content
- f) Product Compliance Certificate

DISPUTE MANAGEMENT

27. The provisions of this tender shall always be subject to Government Notifications, any rules/ guidelines that may be in force from time to time.

- i) All disputes or differences whatsoever arising between the parties out of or in relation to the construction, meaning and operation or effect of these Tender Documents or breach thereof shall be settled amicably. However, if the parties are not able to solve it amicably, the same shall be settled by arbitration in accordance with the provisions of

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

"Arbitration and Conciliation Act 1996" or any statutory modifications or re-enactments thereof and the rules made there under and for the time being in force, shall apply to the arbitration proceedings.

ii) The arbitrator shall be appointed with the mutual consent of both the parties. However, there is a provision of appeal if either party is not satisfied with the arbitration award.

iii) During the arbitration proceedings the Bidder shall continue to work under the Contract unless otherwise directed in writing by the Bank or unless the matter is such that the work cannot possibly be continued until the decision of the arbitrator is obtained.

NUISANCE

28. The Bidder shall not at any time cause or permit anyone to cause any nuisance on the site or do anything which shall cause unnecessary disturbance or inconvenience to the Bank, Owners, Tenants or occupants of other properties near the site and to the customers/ public generally.

NO COMMITMENT TO ACCEPT LOWEST OR ANY TENDER

29. There are no obligations to accept the lowest or any other offer received in response to this notice and Bank is entitled to reject any or all offers without assigning any reasons whatsoever. The Bank will have right to opt for any new technology option for the Banks usage.

FORCE MAJEURE

30. Notwithstanding the provisions of TCC (Terms and Conditions of Contract), the Bidder shall not be liable for forfeiture of its performance security, liquidated damages, or termination for default if and to the extent that the delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.

i) For purposes of this clause, "Force Majeure" means an event beyond the control of the Bidder and not involving the Bidder's fault or negligence and not foreseeable. Such events may include, but are not restricted to, acts of the Bank in its sovereign capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions, and freight embargoes.

ii) If a Force Majeure situation arises, the Bidder shall promptly notify the Bank in writing of such condition and the cause thereof. Unless otherwise directed by the Bank in writing, the Bidder shall continue to perform its obligations under the Contract as far as is reasonably practical, and shall seek all reasonable alternative means for performance not prevented by the Force Majeure event.

EXECUTION OF SLA

31. On completion of the Bid Process, the successful bidder(s) should execute a Service Level Agreement. Bidder(s) should also execute a Non- Disclosure Agreement in the Bank's prescribed format. The agreement/ contract would be signed in Ahmedabad only and stamped as per Gujarat Stamp Act. All the stamp duty shall be borne by the Bidder.

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

RESTRICTION OF FURTHER CONTRACTS

32. The Bidder shall not assign, in whole or in part, its obligations to perform under the Contract, except with the Bank's prior written consent. Consortium and joint venture responses are not allowed, in any case. Also, bidders have to note that no sub-contracting/ sub-letting is allowed.

AMENDMENTS TO CONTRACT

33. No variation in or modification of the terms of the Contract shall be made, except by written amendment, signed by the parties.

CONFIDENTIALITY OF CONTRACT DOCUMENTS & INFORMATION

34. The Bidder shall not, without the Bank's prior written consent, disclose the Contract, or any provision thereof, or any specification, plan, drawing, pattern, sample or information furnished by or on behalf of the bank in connection therewith, to any person other than a person employed by the Bidder in the execution of the Contract.

- i) Disclosure to any such employed person shall be made as confidential and shall extend only as far as may be necessary for purposes of such performance.
- ii) The Bidder shall not, without the Bank's prior written consent, make use of any document or information except for purposes of performing the Contract.
- iii) Any document, other than the Contract itself, shall remain the property of the Bank and shall be returned (in all copies) to the Bank on completion of the Bidder's performance under the Contract, if so required by the Bank.
- iv) Bidder to submit Audited Balance Sheets & FRs within 6 months of close of financial year of the successful Bidder, failing which Bank will have withheld payments. Bank will scrutinize the FRs and may decide to continue the contract or terminate.

PUBLICITY

35. Any publicity by the bidder in which the name of Indian Bank is to be used should be done only with the explicit written permission of Indian Bank.

AUTHORIZED SIGNATORY

36. All pages of this TENDER document and corrigenda must be stamped and initialed by the authorized signatory of the bidder confirming acceptance to all terms and conditions of this TENDER and should be submitted as part of the technical bid.

- a. After completion of selection process the Bank will finalize the contract with the selected Bidder(s). To ensure this both the parties shall also be liable to make authorized officials to be present for discussions.
- b. The Bidder(s) shall submit a Board resolution in case of a company and/or authorization letter duly signed by the authorized signatory naming the official(s) who shall be authorized to hold discussions, time and venue of which shall be intimated to the successful bidder in writing at least 3 calendar days in advance.

****READ THE TENDER DOCUMENTS CAREFULLY BEFORE SUBMISSION****

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

Annexure-I

**Application for participation in TENDER for
Supply and Installation of Fire Extinguishers & Refilling of Fire Extinguishers (including
maintenance of existing Fire Extinguishers)**

(TO BE TYPED ON THE BIDDER'S PRINTED LETTER HEAD)

The Zonal Manager,
Zonal Office Ahmedabad, 3rd Floor, 301-311,
Neelkanth Avenue 1, Opp. Gujarat Vidhyapeeth, C U
Shah College Road, Nr. Income Tax Cross Road,
Ashram Road, Ahmedabad- 380014

Dear Sir,

Subject: Application for participation in Tender for New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers)

1. This has reference to the captioned subject, I/We have carefully perused and understood the criteria mentioned in the Tender Notice released on the website of the Bank.
2. Accordingly, I/We now submit the application form duly completed in all respects, together with certified copies of the following documents as required by you for participation in Tender for New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) to your bank.
3. I/We confirm that all information given herein is true to the best of my/our knowledge. I/We also understand and confirm that if any of the information given is found to be incorrect either fully or partially or any false/fake document is submitted at any stage, you may reject the application summarily and also take any legal action as per law.
4. It is also confirmed that, I/We hereby agree with all the terms and conditions laid down in the application/empanelment documents.

Yours faithfully,

(Proprietor/ Authorized Rep / Bidder's Signature, Name with Seal)

Date:

Encl: Documents: -

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

Annexure-II

BIDDER PROFILE/ TECHNICAL BID
(TO BE TYPED ON THE BIDDER'S PRINTED LETTER HEAD)

SI No	Subject	Details with Page No
1.	Name of the Manufacturer/ Firm/ Company/ Dealer/ Vendor	
2.	Year of Establishment	
3.	Constitution of the Firm (whether Proprietary/ Partnership/ LLP/Pvt. Ltd./Public Ltd.)	
4.	Address of Head Office (in India), including i) Email id ii) Landline and Mobile Number(s)	
5.	Name of the Proprietor/Chairman/ Managing Director/CEO/ Country Head (as the case may be)	
6.	Name(s) and Address of Office at Ahmedabad or districts where Zonal Office Jurisdiction extends, including i) Email id ii) Landline and Mobile Number(s) (Please attach Lease Agreement/ Registration Certificate under Shops and Establishment Act)	
7.	Date of opening of company's Office at Ahmedabad or districts where Zonal Office Jurisdiction extends	
8.	Whether registered with the Registrar of Companies/Registrar of Firms in India. If so, mention number and date and enclose Registration Certificate copy.	
9.	Whether an assess of Income Tax. If so, mention Permanent Account Number and Taxpayer Identification Number. Furnish copies of Income tax clearance certificate	
10.	Whether registered for GST purposes. If so, mention number and date. Also furnish copies of GST certificate.	
11.	Copies of IT Returns last 03 years and GST Return of last one year	
12.	a) Is the Company/Firm a manufacturer of the FIRE EXTINGUISHERS equipment/ accessories/components, etc required by the Bank? If Yes, name of the equipment/ accessories/components, etc and place where manufacturing unit is located. (All manufactured products should be BIS certified) b) if Authorized licensed vendor, agreement with OEM vendor having IS 15683/2018 Licenses (Copy of Proof to be submitted) for manufacturing.	
13.	Is the vendor having URC (Udyam registration Certificate). If Yes, submit the relevant certificate.	
14.	Have you been prequalified by PSUs / Banks (Public/Private)/NBFCs/ Government Departments etc. for New installation, repair and	

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

	maintenance of FIRE EXTINGUISHERS? If Yes, furnish their names, category and date of empanelment. (Enclose empanelment letter)											
15.	Do you have presently running contract with PSUs/ Banks (Public/Private)/NBFCs/ Government Department, etc. for New installation, repair and maintenance of FIRE EXTINGUISHERS? If yes, enclose Performance report/ certificate of running contract.											
16.	Details of Technicians positioned at Ahmedabad and nearby districts mentioned in this TENDER, in format: <table border="1" style="margin-left: 20px;"> <thead> <tr> <th>Sl No</th> <th>Name</th> <th>Qualification</th> <th>Working since</th> <th>Location</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Sl No	Name	Qualification	Working since	Location						
Sl No	Name	Qualification	Working since	Location								
17.	Details of relative(s) employed in Indian Bank, if any. Name: Relation: Branch/Office: Branch/Office last served (if retired): Contact Details:											

Declaration

1. I / We have read and understood the tender documents and I / We understand that if any false information is detected at a later date, any contract made between ourselves and Indian Bank on the Basis of the information given by me / us can be treated as invalid by the Bank and I / We will be solely responsible for the consequences. I / We agree that the decision of Indian Bank in selection of bidders/contractors will be final and binding to me / us.
2. I / We agree that I / We have no objection if enquiries are made about the work listed by me / us here in above and/or in the accompanying sheets.
3. All the information furnished by me/us above here is correct to the best of my/our knowledge and belief.
4. I/We the authorized signatory of the firm undertake to state that our Firm has proper infrastructure and resources and is capable of undertaking New installation, repair and maintenance of Fire Extinguishers (including maintenance of existing Fire Extinguishers) installed in 74 branches/offices of Indian Bank including all rural areas. We further undertake to state that we would be supplying all spare parts of quoted modules for a minimum period of 03 years from the date of Installation.

Place:
Date:
Seal of the Company
Signatory)

Signature
Name:
Designation:
(Authorized

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

Annexure-III

LIST OF ENCLOSURES

TO BE ATTACHED WITH TECHNICAL BIDS

SI No	Subject	Enclosed (Yes/No)	Page No
1.	Certificate of Registration of company/dealership		
2.	Certificate of registration with Income Tax, GST, EPF,ESI, VAT, TAN/TIN etc		
3.	Details of company owned registered office at Ahmedabad or nearby Districts (under the jurisdiction of Zonal Office) with names of employees, address, Tel no., etc Lease agreement and Company Registration Certification such as Shop and Estt. Certificate		
4.	IT Returns and GST Return (past 3 years)		
5.	Empaneled with govt./public sector/banks		
6.	Presently running contract work order with govt./public sector/banks		
7.	STQC/ERTL/ETDC/ISO/BIS/DEALER certificate (As Applicable)		
8.	Customer Reference (other than Indian Bank)		
9.	Documentation: - product, brochures, leaflets, manuals, warranty conditions etc.		
10.	Certificate that Authorized dealer/Firm/OEM or its Sister Agency have not been blacklisted		
11.	Product Certification Details (BIS & CML) for 4.5 kg CO ₂ , 4 Kg ABC (Stored Pressure)		
12.	Agreement with OEM (In case of distributor)		
13.	Facility for Pressure Testing of Fire Extinguishers (Own Facility/ Tie with others). In each case, license and other details to be enclosed.		
	Document(s) in support of any other information		
	Bank Details (Account with Indian Bank)		

- Note:-
1. In absence of any of the information/enclosures or/ and FAKE, WRONG, FICTICIOUS, FLLACIOUS, etc reporting, the tender is likely to be rejected
 2. The Vendor shall produce/provide original of any documents, required by the Bank for Verifications.

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

Annexure-IV

FINANCIAL BID

(TO BE TYPED ON THE BIDDER'S PRINTED LETTER HEAD)

SI No	Description	Make/Brand	BIS & CML	Unit Rate	GST	Total
1.	Portable Fire Extinguisher Carbon Dioxide 4.5 kgs (As per detailed specifications mentioned in the tender document)					
2.	Portable Fire Extinguisher Stored Pressure 4 kgs ABC Type (As per detailed specifications mentioned in the tender document)					
3.	Portable Fire Extinguisher Stored Pressure 2 kgs ABC Type (As per detailed specifications mentioned in the tender document)					
4.	Automatic Modular Fire Extinguisher ABC type 5 kgs (As per detailed specifications mentioned in the tender document)					
5.	Automatic Modular Fire Extinguisher ABC type 10 kgs(As per detailed specifications mentioned in the tender document)					
6.	AMC Charge (2 mandatory visits per year on half-yearly Basis. In addition, visit on call as and when required without any additional charges)					

Charges for Refilling

SI No	Description	Base Rate	GST	Total
1.	Portable Fire Extinguisher Carbon Dioxide 4.5 kgs			
2.	Portable Fire Extinguisher Carbon Dioxide 3.2 kgs			
3.	Portable Fire Extinguisher Carbon Dioxide 2 kgs			
4.	Portable Fire Extinguisher Stored Pressure 4 kgs ABC Type			
5.	Portable Fire Extinguisher Stored Pressure 6 kgs ABC Type			
6.	Automatic Modular Fire Extinguisher ABC type 5 kgs			

Seal & Signature of Vendor

RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS & REFILLING OF FIRE EXTINGUISHERS (INCLUDING MAINTENANCE OF EXISTING FIRE EXTINGUISHERS)

7.	Automatic Modular Fire Extinguisher ABC type10 kgs			
8.	Automatic Modular Fire Extinguisher Clean Agent type 5 kgs			
9	Automatic Modular Fire Extinguisher Clean Agent type 10 kgs			

Charges for Hydraulic Pressure Testing

SI No	Description	Base Rate	GST	Total
1.	Portable Fire Extinguisher Carbon Dioxide 4.5 kgs			
2.	Portable Fire Extinguisher Carbon Dioxide 3.2 kgs			
3.	Portable Fire Extinguisher Carbon Dioxide 2 kgs			
4.	Portable Fire Extinguisher Stored Pressure 4 kgs ABC Type			
5.	Portable Fire Extinguisher Stored Pressure 6 kgs ABC Type			
6.	Automatic Modular Fire Extinguisher ABC type 5 kgs			
7.	Automatic Modular Fire Extinguisher ABC type10 kgs			
8	Automatic Modular Fire Extinguisher Clean Agent type 5 kgs			
9.	Automatic Modular Fire Extinguisher Clean Agent type 10 kgs			

Place:
Date:
Seal of the Company
Signatory)

Signature
Name:
Designation:
(Authorized